



# Britannia Fire Ltd

Britannia Fire Ltd  
 Ashwellthorpe Industrial Estate, Norwich,  
 NR16 1ER  
 Tel: 01508 488416  
 sales@britannia-fire.co.uk  
 www.britannia-fire.co.uk



Fire Industry Association

## FIREWORLD EXTINGUISHER INSTALLATION/COMMISSIONING CERTIFICATE

CUSTOMER NAME - Caister St Edmund and Bixley Parish Council	JOB NUMBER -
SITE ADDRESS - Arminghall Village Hall, Arminghall Lane, Arminghall, Norwich, NR14 8SF	INVOICE ADDRESS -

WORK CARRIED OUT			
Equipment	Size	Commission	Wall Hang
P50 Foam	6ltr		2

Additional Items	Quantity
Extinguisher ID sign	2
Fire call point ID sign	
Fire action notice	
Fire safety log book	

COMPETENCY TRAINING ROUTINE -
<b>Fire Extinguisher</b>
Visually inspect the extinguisher for damage, check the tamper seal is in place and the safety pin is secure.
Remove any dust or dirt with a clean moist cloth. Do not use chemicals.
Turn the extinguisher upside down to check the extinguisher is not older than ten years. Do not rest the extinguisher on the handle. If the extinguisher is old than ten years, the unit requires an overhaul.
Visually ensure that both gauge needles are in the green segment of the pressure gauge. If the needle is in either of the red sections, the extinguisher must be returned to the manufacturer for further investigation.
Check both gauges with the magnet supplied in the base to ensure the pin moves freely.
Record the yearly inspection in the table on the rear of the extinguisher and also in the Fire log book.

Britannia Fire Ltd have installed and commissioned the P50 fire extinguishers within the premises identified above in accordance with the selection requirements indicated by BS5306 part 3 and part 8 as far as applicable and in accordance with the manufacturer's instructions. <b>According to BS5306 part 3, it is the duty of the responsible person in the premises to inspect extinguishers at regular intervals.</b>	
Technician Name _____ Jordan Brice _____ Signature _____	I have understood the training to enable me to carry out the annual visual inspection on the P50 Fire Extinguishers according to the manufacturers instructions.
Date:- 10 / 02 / 2026 LOG BOOK COMPLETED? YES/NO	CUSTOMER SIGNATURE _____ POSITION _____ PRINT NAME _____